

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0027**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**“VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9927 (See ANNEX B) 9857 & 9957 (See ANNEX C) Series” Panic Exit Devices**

**Intended use: For use on single and double leaf doors on escape routes, including fire resisting door assemblies**

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Mechanical Test Evidence :</b> 179381 / 181858 / 183724 / 188932 / 308944 / WIL 323082 / WIL 328796 / WIL 334894 / WIL 345801 / WIL 350699 / WIL 356933 / WIL 377733 / & WIL 389644 <b>Fire Test Evidence :</b> WF 127579 / WF 131072 & WF 132276 AR Iss 4		
<b>Clause 4.2.1 Ability to release</b> (for doors on panic routes) Release function Panic exit device mounting Exposed edges and corners Double doorset Single doorset Bar installation Bar length Bar projection Bar end Operating bar face Test rod Door face gap Accessible gap Door free movement Top vertical bolt Covers for vertical rods Keepers Keepers dimensions Door mass and dimensions  Outside access device Release forces  Security requirement	< 1 sec Pass > 0,5 mm Pass – (See Annex A&B) Pass – (See Annex A/B & C) Z < 150 mm > 60% W< 100mm Pass > 18 mm Pass > 25 mm Pass Pass Pass – (See Annex B&C) Pass – (See Annex B&C) Pass Pass – (See Annex B&C) Door mass ≤ 200Kg, door height ≤ 2500mm, door width ≤ 1016mm Pass < 80N with the door unloaded, and < 220N with the door loaded with 1 000N Grade 2	EN 1125:2008
<b>Clause 4.2.1 Durability of ability to release against aging and degradation</b> (for doors on panic routes) Corrosion resistance Temperature range  Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance –Horizontal bar Abuse resistance –Vertical rod Final examination	Grade 3 : 96 Hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C°  NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 1 000N 500N - (See Annex B&C) < 80N with the door unloaded, and < 220N with the door loaded with 1 000N	

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0027**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**“VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9927 (See ANNEX B) 9857 & 9957 (See ANNEX C) Series” Panic Exit Devices**

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Clause 4.2.1 Self closing ability C</b> (for fire/smoke doors on escape routes) Re-engagement force	< 50N	EN 1125:2008
<b>Clause 4.2.1 Durability of self closing ability C against aging and degradation</b> (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50N	
<b>Clause 4.2.1 Resistance to fire E (integrity) and I (insulation)</b> (For use on fire doors) Suitability of panic exit devices for use on fire resisting doorsets assemblies –	Grade B : Suitable for use on fire door assemblies. ( Please note the fire evidence does not cover any of the outside access devices )	
Additional requirements		
<b>Clause 4.1.25 Control of Dangerous substances</b>	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the Device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0027**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### “VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9927 (See ANNEX B) 9857 & 9957 (See ANNEX C) Series” Panic Exit Devices

Von Duprin Product Code	Single Door	Double Door	Approved with Alternate Keepers and sockets			
			299	299F	1609	304L
<b>ANNEX A – 1 Point Rim Latch Locking</b>						
99 99-F Rim	√	√	√	√	√	-----
EL99 Rim	√	√	√	√	√	-----
QELA 99 Rim	√	√	√	√	√	-----
98 98-F Rim	√	√	√	√	√	-----
33A 33A-F Rim	√	√	√	√	√	-----
EL33A Rim	√	√	√	√	√	-----
35A 35A-F Rim	√	√	√	√	√	-----
EL35A Rim	√	√	√	√	√	-----
22 22-F Rim	√	√	√	√	√	-----
<b>ANNEX B – 2 Point Vertical Locking</b>						
9927 9927-F Vertical	√	√	√	√	-----	√
9827 9827-F Vertical	√	√	√	√	-----	√
3327A 3327A-F Vertical	√	√	√	√	-----	√
3527A 3527A-F Vertical	√	√	√	√	-----	√
2227 2227-F Vertical	√	√	√	√	-----	√
<b>ANNEX C – 3 Point Vertical &amp; Rim Latch Locking</b>						
9857 9857-F Vertical	√	-----	√	√	-----	√
9957 9957-F Vertical	√	-----	√	√	-----	√
<b>Accessories : 99, 99-F, EL99 Series, 98, 98-F, EL98 Series, 35A, 35A-F, EL35A Series, 33A, 33A-F, EL33A Series, 22 &amp; 22-F Series</b>						
99 Series	√	√	990DT, 990NL, 990TP, 991K, 992L (Std), options #01, #02, #03, #07, #12 & #17, KEYLEX 2100 & KEYLEX 700			
98 Series	√	√	990DT, 990NL, 990TP, 991K, 992L (Std), options #01, #02, #03, #07, #12 & #17, KEYLEX 2100 & KEYLEX 700			
35A Series	√	√	360L, 360T, 386NL, 386DT, 388, KEYLEX 2100 & KEYLEX 700			
33A Series	√	√	360L, 360T, 386NL, 386DT, 388, KEYLEX 2100 & KEYLEX 700			
22 Series	√	√	210DT, 210NL, 210K, 230L, 230DT, 230NL, 230TP, 230L, KEYLEX 2100 & KEYLEX 700			

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0027**

Placed on the market under the Name or Trade Mark of

**Allegion (UK) Ltd  
35 Rocky Lane  
Birmingham  
West Midlands  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant

**E014110-4**

**This is coded format and the information is held by the Approved Body**

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

**EN 1125:2008**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **22/03/2021** and re-issued **29/08/2024** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **28/08/2027**

ERO Project Reference: **034621 P2356**



Pascal Coget  
General Manager – European Certification

CSF408-NL 8.0