

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7570

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

“VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9927 (See ANNEX B) 9857 & 9957 (See ANNEX C) Series” Panic Exit Devices

Intended use: For use on single and double leaf doors on escape routes, including fire resisting door assemblies

Essential characteristics	Performance	Designated Standard
Mechanical Test Evidence : 179381 / 181858 / 183724 / 188932 / 308944 / WIL 323082 / WIL 328796 / WIL 334894 / WIL 345801 / WIL 350699 / WIL 356933 / WIL 377733 / & WIL 389644 Fire Test Evidence : WF 127579 / WF 131072 & WF 132276 AR Iss 4		
Clause 4.2.1 Ability to release (for doors on panic routes) Release function Panic exit device mounting Exposed edges and corners Double doorset Single doorset Bar installation Bar length Bar projection Bar end Operating bar face Test rod Door face gap Accessible gap Door free movement Top vertical bolt Covers for vertical rods Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass > 0,5 mm Pass – (See Annex A&B) Pass – (See Annex A/B & C) Z < 150 mm > 60% W < 100mm Pass > 18 mm Pass > 25 mm Pass Pass Pass – (See Annex B&C) Pass – (See Annex B&C) Pass Pass – (See Annex B&C) Door mass ≤ 200Kg, door height ≤ 2500mm, door width ≤ 1016mm Pass < 80N with the door unloaded, and < 220N with the door loaded with 1 000N Grade 2	EN 1125:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on panic routes) Corrosion resistance Temperature range Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance –Horizontal bar Abuse resistance –Vertical rod Final examination	Grade 3 : 96 Hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 1 000N 500N - (See Annex B&C) < 80N with the door unloaded, and < 220N with the door loaded with 1 000N	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7570

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

“VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9927 (See ANNEX B) 9857 & 9957 (See ANNEX C) Series” Panic Exit Devices

Essential characteristics	Performance	Designated Standard
Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50N	EN 1125:2008
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (For use on fire doors) Suitability of panic exit devices for use on fire resisting doorsets assemblies – Additional requirements	Grade B : Suitable for use on fire door assemblies. (Please note the fire evidence does not cover any of the outside access devices)	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the Device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7570

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

“VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9927 (See ANNEX B) 9857 & 9957 (See ANNEX C) Series” Panic Exit Devices

Von Duprin Product Code	Single Door	Double Door	Approved with Alternate Keepers and sockets			
			299	299F	1609	304L
ANNEX A – 1 Point Rim Latch Locking						
99 99-F Rim	√	√	√	√	√	-----
EL99 Rim	√	√	√	√	√	-----
QELA 99 Rim	√	√	√	√	√	-----
98 98-F Rim	√	√	√	√	√	-----
33A 33A-F Rim	√	√	√	√	√	-----
EL33A Rim	√	√	√	√	√	-----
35A 35A-F Rim	√	√	√	√	√	-----
EL35A Rim	√	√	√	√	√	-----
22 22-F Rim	√	√	√	√	√	-----
ANNEX B – 2 Point Vertical Locking						
9927 9927-F Vertical	√	√	√	√	-----	√
9827 9827-F Vertical	√	√	√	√	-----	√
3327A 3327A-F Vertical	√	√	√	√	-----	√
3527A 3527A-F Vertical	√	√	√	√	-----	√
2227 2227-F Vertical	√	√	√	√	-----	√
ANNEX C – 3 Point Vertical & Rim Latch Locking						
9857 9857-F Vertical	√	-----	√	√	-----	√
9957 9957-F Vertical	√	-----	√	√	-----	√
Accessories : 99, 99-F, EL99 Series, 98, 98-F, EL98 Series, 35A, 35A-F, EL35A Series, 33A, 33A-F, EL33A Series, 22 & 22-F Series						
99 Series	√	√	990DT, 990NL, 990TP, 991K, 992L (Std), options #01, #02, #03, #07, #12 & #17, KEYLEX 2100 & KEYLEX 700			
98 Series	√	√	990DT, 990NL, 990TP, 991K, 992L (Std), options #01, #02, #03, #07, #12 & #17, KEYLEX 2100 & KEYLEX 700			
35A Series	√	√	360L, 360T, 386NL, 386DT, 388, KEYLEX 2100 & KEYLEX 700			
33A Series	√	√	360L, 360T, 386NL, 386DT, 388, KEYLEX 2100 & KEYLEX 700			
22 Series	√	√	210DT, 210NL, 210K, 230L, 230DT, 230NL, 230TP, 230L, KEYLEX 2100 & KEYLEX 700			

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7570

Placed on the market under the Name of

**Allegion (UK) Ltd
35 Rocky Lane
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant:

E014110-4

This is coded format, and the information is held by the Approved Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1125 : 2008

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and re-issued on **23/08/2024** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **22/08/2027**



0087



**Paul Duggan
Certification Manager**

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**